

# Fire Company Hazard Survey

**BUSINESS:** \_\_\_\_\_ **ADDRESS:** \_\_\_\_\_

## A. BUILDING EXTERIOR

**BLDG:** \_\_\_\_\_

Yes    No    N/A

- Is the building address plainly visible from the street and a minimum of 4" numbers?
- Is the fire lane for emergency vehicles clear and unobstructed for vehicle access?
- Are all dumpsters at least 5' away from combustibles walls and roof eaves? General roll carts are permitted.

## B. MEANS OF EGRESS

- Are aisles, stairs, and exits clear and unobstructed?
- Do all exit doors open easily from the inside?
- Do doors with panic hardware have no other locking devices?
- Do exit doors have only one approved locking device?
- Are the exit and emergency lights working?

## C. FIRE EXTINGUISHERS

- Are fire extinguishers provided?
- Do extinguishers have a current inspection tag?
- Are extinguishers easily seen, accessible, unobstructed by merchandise and storage items, and within 75' maximum travel distance?
- Are extinguishers that are less than 40 lbs. mounted with the top between 3.5' and 5' from the floor? Extinguishers over 40 lbs. can be mounted no higher than 3.5'.

## D. ELECTRICAL

- Are all electrical cords in good condition with no cuts, nicks, splices, or loose connections?
- Are extension cords being used properly as temporary wiring only?
- Are multi-plug outlets plugged directly into an outlet?
- Are all junction boxes enclosed with approved covers and/or are all wiring splices inside the junction box?
- Do electrical panels have 30" of clearance for easy access?

## E. STORAGE

- In storage areas, is there a 2' clearance from the storage to the ceiling?
- Are all exit ways, stairways or ramps, near heating devices, and in electrical or mechanical rooms, free of combustibles materials?
- Are flammable and combustible liquids for maintenance in excess of 10 gallons stored in an approved cabinet?

**Signature of Owner/Occupant:** \_\_\_\_\_ **Date:** \_\_\_\_\_

**Performed by:** \_\_\_\_\_