

Hazard Survey Classification

Level 1

Exits compromised, Imminent fire hazard (electrical, flammable storage)
Improper cooking procedures, residence

Level 2

No Fire Extinguishers, open junction boxes, switches, outlets or panel boxes
Exits with unapproved locking mechanisms
Obstructed fire lane
Required exit signs
Improper electrical wiring, extension cords, multi plugs, clearance in front of electrical panel

Level 3

Fire Extinguishers past due for service
Dumpsters too close to buildings
Exit lights or illuminated exit path
Improper storage

Level 4

Address not on building
Fire extinguishers not mounted properly